

Job No

## MATERIAL TESTING LABORATORY MILITARY ENGINEER SERVICES (MES) TEST RESULT FOR FINENESS MODULUS(F.M.) OF SAND.

Page No: 104

Copy no : 02

: 85/2024-2025(Sand).

Name of Clint: GE (Army) Rangpur.Ref ltr no: EinC/110 of 2024-2025/07/E

: EinC/110 of 2024-2025/07/E-6 Dt.14 May'2025

Project Name : Construction of Drain & Box Culvert.

Sample Specimen : Sylhet Sand

Dt of sample collection :17 May'2025

## Test Standard : ASTM/BS

Sieve Size	Wt of Material	Percentage Matarial	Cumulative % Retained	%Finer	Remarks
	Retainned(gms)	Retained(Round)			
#4	0.00	0.00	0.00		
# 8	23.45	5.86	5.86		
#16	145.51	36.38	42.24		
# 30	163.32	40.83	83.07		
# 50	59.02	14.76	97.83		FM= 3.29
#100	8.43	2.11	99.93		
# 200	0.03	0.01			
#Pan	0.17	0.04			
			Σ= 328.93		

Cautions :

1 Samples as supplied to the laboratory have been tested. The laboratory authority does not bear any responsibility as to the representative character of the sample to be tested.

2 It is recommended that samples are sent in a sealed cover/packet/container under signature of the competent authority

3 In oder to be avoid fraudulent fabrication of the test result, it is recommended that test reports should be collected by duly authorized person and not by the contractor/supplier. **Observation on Specimen(if any):** 

1

Laboratory Technician

Test Performed By

Vetted By

Permissable Value:

1.For Sylhet/Domar sand minimum FM will be = 2.50 2.For Local sand minimum FM will be = 1.5 3.For Vitty sand minimum FM will be = 0.80